



**Masters** Company Inc.  
Creative Solutions for Water Management

## POLYAMINE PRODUCTS

Below is a test method used for determining PolyAmine in boiler treatments. The MP-9727 is manufactured exclusively for use with MCI's MP-9737M hand-held colorimeter and is designed to be a disposable PolyAmine test, where the sample vials can be discarded after use to allow for better test results each time. The MP-9727 reagent pack can also be used in conjunction with other meters which read at 530NM and can accept a 10ml sample size.

CAT. NO.	PRODUCT DESCRIPTION
MP-9727	Low Range PolyAmine Test Pack (30 Tests with Disposable Vials) *MP-9727 is used in conjunction with Masters MP-9737M colorimeter or in similar meters which read at 530nm and utilize a 10ml sample.
MP-9737M	MCI Multi-Parameter Photometer Test Kit, Battery Operated, Complete with Batteries, Test Vials, Instruction Booklet and Foam Lined Case